

NBSD LEAD IN DRINKING WATER IN PRIORITY AREAS RESULTS

Special Note: "J" value indicates the sample result is an estimated concentration.

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	Follow-up Flushing		Proposed Corrective Action	Corrective Action Planned/Completed
						First Draw Sample	30-Sec Flush		
		Sink	B15_RM_1_S1	9/6/2014	1.59J	n/a	n/a	n/a	n/a
		Sink	B15_JANITOR_S1	9/6/2014	0.578J	n/a	n/a	n/a	n/a
		Sink	B15_RR2_S1	9/6/2014	0.468J	n/a	n/a	n/a	n/a
		Sink	B15_RM_126_S1	9/6/2014	0.745J	n/a	n/a	n/a	n/a
		Sink	B15_RM_126_S2	9/6/2014	0.528J	n/a	n/a	n/a	n/a
		Sink	B15_RM_126_S3	9/6/2014	0.874J	n/a	n/a	n/a	n/a
		Sink	B15_RM_126_SP1	9/6/2014	CANCELLED	CANCELLED	CANCELLED	CANCELLED	CANCELLED
		Sink	B15_RM_126_SP2	9/6/2014	12.0	n/a	n/a	n/a	n/a
		Sink	B15_RM_102_S1	9/6/2014	1.92J	n/a	n/a	n/a	n/a
		Sink	B15_RR3_S1	9/6/2014	0.867J	n/a	n/a	n/a	n/a
		Sink	B15_RM_113_S1	9/6/2014	0.246J	n/a	n/a	n/a	n/a
		Sink	B15_RM_118_S1	9/6/2014	0.484J	n/a	n/a	n/a	n/a
		Sink	B15_RM_118_S2	9/6/2014	0.352J	n/a	n/a	n/a	n/a
		Sink	B15_RM_119_S1	9/6/2014	1.26J	n/a	n/a	n/a	n/a
		Sink	B15_RM_119_S2	9/6/2014	0.647J	n/a	n/a	n/a	n/a
		Sink	B15_RM_119_S2A	9/6/2014	1.37J	n/a	n/a	n/a	n/a
		Sink	B15_RM_119_S3	9/6/2014	0.474J	n/a	n/a	n/a	n/a
		Sink	B15_RM_119_S3A	9/6/2014	0.516J	n/a	n/a	n/a	n/a
		Sink	B15_RM_120_S1	9/6/2014	0.998J	n/a	n/a	n/a	n/a
		Sink	B15_RM_120_S1A	9/6/2014	0.394J	n/a	n/a	n/a	n/a
		Sink	B15_RM_120_S2	9/6/2014	0.912J	n/a	n/a	n/a	n/a
		Sink	B15_RM_120_S2A	9/6/2014	0.856J	n/a	n/a	n/a	n/a
		Sink	B15_RM_120_S3	9/6/2014	0.461J	n/a	n/a	n/a	n/a
		Sink	B15_RM_121_S2	9/6/2014	1.11J	n/a	n/a	n/a	n/a
		Sink	B15_RM_121_S2A	9/6/2014	2.83J	n/a	n/a	n/a	n/a
		Sink	B15_RM_121_S3	9/6/2014	14.5	n/a	n/a	n/a	n/a
		Sink	B15_RM_121_S3A	9/6/2014	1.51J	n/a	n/a	n/a	n/a
		Sink	B15_RM_122_S1	9/6/2014	1.27J	n/a	n/a	n/a	n/a
		Sink	B15_RM_122_S1A	9/6/2014	0.681J	n/a	n/a	n/a	n/a
		Sink	B15_RM_122_S2	9/6/2014	1.21J	n/a	n/a	n/a	n/a
		Sink	B15_RM_122_S2A	9/6/2014	2.53J	n/a	n/a	n/a	n/a
		Sink	B15_RM_122_S3	9/6/2014	1.45J	n/a	n/a	n/a	n/a
		Sink	B15_RM_123_S1	9/6/2014	0.818J	n/a	n/a	n/a	n/a
		Sink	B15_RM_123_S2	9/6/2014	1.07J	n/a	n/a	n/a	n/a
		Sink	B15_RM_123_S3	9/6/2014	0.770J	n/a	n/a	n/a	n/a
		Sink	B15_RM_123_S3A	9/6/2014	0.813J	n/a	n/a	n/a	n/a
		Sink	B15_RM_124_S1	9/6/2014	4.31J	n/a	n/a	n/a	n/a

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
15	San Diego Navy Medical Center - CDC	Sink	B15_RM_124_S1A	9/6/2014	0.750J	n/a	n/a	n/a	n/a
		Sink	B15_RM_124_S2	9/6/2014	4.59J	n/a	n/a	n/a	n/a
		Sink	B15_RM_124_S3	9/6/2014	1.49J	n/a	n/a	n/a	n/a
		Sink	B15_RM_125_S1	9/6/2014	0.509J	n/a	n/a	n/a	n/a
		Sink	B15_RM_125_S2	9/6/2014	0.769J	n/a	n/a	n/a	n/a
		Sink	B15_RM_125_S2A	9/6/2014	1.67J	n/a	n/a	n/a	n/a
		Sink	B15_RM_125_S3	9/6/2014	0.588J	n/a	n/a	n/a	n/a
		Sink	B15_RM_125_S3A	9/6/2014	0.646J	n/a	n/a	n/a	n/a
		Sink	B15_RM_105_S1	9/6/2014	0.964J	n/a	n/a	n/a	n/a
		Sink	B15_RM_105_S1A	9/6/2014	0.423J	n/a	n/a	n/a	n/a
		Sink	B15_RM_105_S2	9/6/2014	0.578J	n/a	n/a	n/a	n/a
		Sink	B15_RM_105_S2A	9/6/2014	3.84J	n/a	n/a	n/a	n/a
		Sink	B15_RM_105_S3	9/6/2014	2.56J	n/a	n/a	n/a	n/a
		Sink	B15_RM_106_S1	9/6/2014	0.394J	n/a	n/a	n/a	n/a
		Sink	B15_RM_106_S2	9/6/2014	0.916J	n/a	n/a	n/a	n/a
		Sink	B15_RM_106_S2A	9/6/2014	1.61J	n/a	n/a	n/a	n/a
		Sink	B15_RM_106_S3	9/6/2014	1.02J	n/a	n/a	n/a	n/a
		Sink	B15_RM_106_S3A	9/6/2014	0.497J	n/a	n/a	n/a	n/a
		Sink	B15_RM_107_S1	9/6/2014	0.756J	n/a	n/a	n/a	n/a
		Sink	B15_RM_107_S1A	9/6/2014	1.16J	n/a	n/a	n/a	n/a
		Sink	B15_RM_107_S2	9/6/2014	0.544J	n/a	n/a	n/a	n/a
		Sink	B15_RM_107_S2A	9/6/2014	0.484J	n/a	n/a	n/a	n/a
		Sink	B15_RM_107_S3	9/6/2014	0.630J	n/a	n/a	n/a	n/a
		Sink	B15_RM_108_S1	9/6/2014	5.08	n/a	n/a	n/a	n/a
		Sink	B15_RM_108_S2	9/6/2014	1.22J	n/a	n/a	n/a	n/a
		Sink	B15_RM_108_S2A	9/6/2014	0.874J	n/a	n/a	n/a	n/a
		Sink	B15_RM_108_S3	9/6/2014	1.26J	n/a	n/a	n/a	n/a
		Sink	B15_RM_108_S3A	9/6/2014	0.518J	n/a	n/a	n/a	n/a
		Sink	B15_RM_109_S1	9/6/2014	0.882J	n/a	n/a	n/a	n/a
		Sink	B15_RM_109_S1A	9/6/2014	0.772J	n/a	n/a	n/a	n/a
		Sink	B15_RM_109_S2	9/6/2014	0.435J	n/a	n/a	n/a	n/a
		Sink	B15_RM_109_S2A	9/6/2014	1.03J	n/a	n/a	n/a	n/a
		Sink	B15_RM_109_S3	9/6/2014	0.412J	n/a	n/a	n/a	n/a
Sink	B15_RM_110_S1	9/6/2014	0.380J	n/a	n/a	n/a	n/a		
Sink	B15_RM_110_S2	9/6/2014	0.495J	n/a	n/a	n/a	n/a		
Sink	B15_RM_110_S2A	9/6/2014	1.78J	n/a	n/a	n/a	n/a		
Sink	B15_RM_110_S3	9/6/2014	0.290J	n/a	n/a	n/a	n/a		
Sink	B15_RM_110_S3A	9/6/2014	0.318J	n/a	n/a	n/a	n/a		
Sink	B15_RM_111_S1	9/6/2014	0.380J	n/a	n/a	n/a	n/a		
Sink	B15_RM_111_S2	9/6/2014	0.608J	n/a	n/a	n/a	n/a		
Sink	B15_RM_111_S1A	9/6/2014	0.548J	n/a	n/a	n/a	n/a		
Sink	B15_RM_111_S3	9/6/2014	2.65J	n/a	n/a	n/a	n/a		
Sink	B15_RM_111_S2A	9/6/2014	1.41J	n/a	n/a	n/a	n/a		

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
		Sink	B15_RM_112_S1	9/6/2014	1.21J	n/a	n/a	n/a	n/a
		Sink	B15_RM_112_S2	9/6/2014	3.99J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B15_BB1	9/6/2014	1.14J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B15_BB2	9/6/2014	1.44J	n/a	n/a	n/a	n/a
		Hose Bib	B15_HB1	9/6/2014	4.23J	n/a	n/a	n/a	n/a
		Hose Bib	B15_HB2	9/6/2014	2.76J	n/a	n/a	n/a	n/a
		Hose Bib	B15_HB3	9/6/2014	2.19J	n/a	n/a	n/a	n/a
		Hose Bib	B15_HB4	9/6/2014	3.28J	n/a	n/a	n/a	n/a
		Hose Bib	B15_HB5	9/6/2014	5.15	n/a	n/a	n/a	n/a
		Restroom Sink	B15_RR1_S1_SERVCONN	9/6/2014	0.875J	n/a	n/a	n/a	n/a
		Laundry Room Eyewash Fountain	B15_RM1_S1A	9/6/2014	65.6	n/a	n/a	Resampling of fixture with new supply line	Tap capped and secured on 9-23-14. Supply line for fixture replaced and subsequently resampled on 14Mar15. Sampling results returned 1.02J ppb. No further action at this time.

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
		Bubbler Fountain	B3653_BB1	9/6/2014	0.316J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3653_BB2	9/6/2014	0.317J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3653_BB3	9/6/2014	1.58J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3653_BB4	9/6/2014	0.559J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3653_BB5	9/6/2014	0.619J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3653_BB6	9/6/2014	1.48J	n/a	n/a	n/a	n/a
		Sink	B3653_PRETD7S1-SRVCN	9/6/2014	1.37J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_1_S1	9/6/2014	0.596J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_2_S1	9/6/2014	0.498J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_3_S1	9/6/2014	0.539J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_4_S1	9/6/2014	0.918J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_5_S1	9/6/2014	0.493J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_6_S1	9/6/2014	0.646J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_7_S1	9/6/2014	1.45J	n/a	n/a	n/a	n/a
		Sink	B3653_KITCHEN_S1	9/6/2014	0.827J	n/a	n/a	n/a	n/a
		Sink	B3653_KITCHEN_S2	9/6/2014	0.816J	n/a	n/a	n/a	n/a
		Sink	B3653_KITCHEN_S3	9/6/2014	0.549J	n/a	n/a	n/a	n/a
		Sink	B3653_KITCHEN_S4	9/6/2014	1.36J	n/a	n/a	n/a	n/a
		Sink	B3653_KITCHEN_S5	9/6/2014	0.904J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL4_S1	9/6/2014	0.656J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL4_S2	9/6/2014	0.459J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL4_S2A	9/6/2014	0.618J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL3_S1	9/6/2014	0.930J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL3_S1A	9/6/2014	0.490J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL3_S2	9/6/2014	0.510J	n/a	n/a	n/a	n/a
		Sink	B3653_JANITRCLSET_S1	9/6/2014	0.511J	n/a	n/a	n/a	n/a
		Sink	B3653_LAUNDRY_S1	9/6/2014	0.755J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_1_S2	CANCELLED	CANCELLED	CANCELLED	CANCELLED	CANCELLED	CANCELED
		Sink	B3653_PRE-TODD_2_S2	9/6/2014	1.07J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_3_S2	9/6/2014	0.929J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_4_S2	9/6/2014	1.18J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_5_S2	9/6/2014	1.03J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_6_S2	9/6/2014	1.14J	n/a	n/a	n/a	n/a
		Sink	B3653_PRE-TODD_7_S2	9/6/2014	0.669J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL4_S3	9/6/2014	1.13J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL4_S4	9/6/2014	1.15J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL3_S3	9/6/2014	1.12J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL3_S4	9/6/2014	1.00J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL2_S3	9/6/2014	1.35J	n/a	n/a	n/a	n/a
		Sink	B3653_PRECHOOL2_S4	9/6/2014	1.45J	n/a	n/a	n/a	n/a

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
3653	NBSD CDC	Sink	B3653_PRESCHOOL1_S3	9/6/2014	1.41J	n/a	n/a	n/a	n/a
		Sink	B3653_PRESCHOOL1_S4	9/6/2014	1.20J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_6_S3	9/6/2014	0.960J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_6_S4	9/6/2014	1.08J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_5_S3	9/6/2014	1.02J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_5_S4	9/6/2014	1.07J	n/a	n/a	n/a	n/a
		Sink	B3653_BREAK_ROOM_S1	9/6/2014	0.909J	n/a	n/a	n/a	n/a
		Sink	B3653_PRESCHOOL2_S1	9/6/2014	0.610J	n/a	n/a	n/a	n/a
		Sink	B3653_PRESCHOOL2_S2	9/6/2014	0.557J	n/a	n/a	n/a	n/a
		Sink	B3653_PRESCHOOL2_S2A	9/6/2014	0.550J	n/a	n/a	n/a	n/a
		Sink	B3653_PRESCHOOL1_S1	9/6/2014	0.536J	n/a	n/a	n/a	n/a
		Sink	B3653_PRESCHOOL1_S1A	9/6/2014	0.761J	n/a	n/a	n/a	n/a
		Sink	B3653_PRESCHOOL1_S2	9/6/2014	0.695J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_6_S1	9/6/2014	0.476J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_6_S2	9/6/2014	0.457J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_6_S2A	9/6/2014	0.706J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_5_S1	9/6/2014	0.518J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_5_S1A	9/6/2014	0.473J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_5_S2	9/6/2014	0.593J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_4_S1	9/6/2014	0.556J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_4_S1A	9/6/2014	0.522J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_4_S2	9/6/2014	0.719J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_3_S1	9/6/2014	0.536J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_3_S2	9/6/2014	0.608J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_3_S2A	9/6/2014	0.753J	n/a	n/a	n/a	n/a
		Sink	B3653_SHOWER_RR_S1	9/6/2014	0.433J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_1_S1	9/6/2014	0.541J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_2_S1	9/6/2014	0.557J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_3_S1	9/6/2014	0.626J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_4_S1	9/6/2014	0.548J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_5_S1	9/6/2014	0.597J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_6_S1	9/6/2014	0.816J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_7_S1	9/6/2014	0.701J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_1_S1	9/6/2014	0.510J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_1_S1A	9/6/2014	1.48J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_1_S2	9/6/2014	0.710J	n/a	n/a	n/a	n/a
Sink	B3653_TODDLERS_2_S1	9/6/2014	0.499J	n/a	n/a	n/a	n/a		
Sink	B3653_TODDLERS_2_S2	9/6/2014	0.380J	n/a	n/a	n/a	n/a		
Sink	B3653_TODDLERS_2_S2A	9/6/2014	0.598J	n/a	n/a	n/a	n/a		
Hose Bib	B3653_HB1	9/6/2014	3.99J	n/a	n/a	n/a	n/a		
Hose Bib	B3653_HB2	9/6/2014	2.08J	n/a	n/a	n/a	n/a		
Hose Bib	B3653_HB3	9/6/2014	4.73J	n/a	n/a	n/a	n/a		
Hose Bib	B3653_HB4	9/6/2014	1.78J	n/a	n/a	n/a	n/a		

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
		Hose Bib	B3653_HB5	9/6/2014	4.53J	n/a	n/a	n/a	n/a
		Hose Bib	B3653_HB6	9/6/2014	3.53J	n/a	n/a	n/a	n/a
		Hose Bib	B3653_HB7	9/6/2014	1.96J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_1_S2	9/6/2014	13.7	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_2_S2	9/6/2014	21.2	n/a	n/a	Cap and secure	Never been used to consume water - exempt from town hall requirement. Tap capped and secured on 9-23-14.
		Sink	B3653_INFANT_3_S2	9/6/2014	4.33J	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_4_S2	9/6/2014	14.3	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_5_S2	9/6/2014	15.3	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_6_S2	9/6/2014	14.1	n/a	n/a	n/a	n/a
		Sink	B3653_INFANT_7_S2	9/6/2014	20.2	n/a	n/a	Cap and secure	Never been used to consume water - exempt from town hall requirement. Tap capped and secured on 9-23-14.
		Sink	B3653_TODDLERS_4_S3	9/6/2014	1.24J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_4_S4	9/6/2014	1.20J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_3_S3	9/6/2014	1.07J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_3_S4	9/6/2014	1.28J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_2_S3	9/6/2014	2.08J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_2_S4	9/6/2014	1.13J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_1_S3	9/6/2014	1.21J	n/a	n/a	n/a	n/a
		Sink	B3653_TODDLERS_1_S4	9/6/2014	1.04J	n/a	n/a	n/a	n/a

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
4867	Murphy Canyon - Youth Center	Sink	B4867_ROOM_A_S1	9/7/2014	4.58J	n/a	n/a	n/a	n/a
		Sink	B4867_ROOM_B_S1	9/7/2014	3.80J	n/a	n/a	n/a	n/a
		Sink	B4867_ROOM_C_S1	9/7/2014	2.47J	n/a	n/a	n/a	n/a
		Sink	B4867_KITCHEN_S1	9/7/2014	2.24J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B4867_BB1	9/7/2014	1.44J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B4867_BB2	9/7/2014	1.48J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B4867_BB3	9/7/2014	2.67J	n/a	n/a	n/a	n/a
		Hose Bib	B4867_HB1	9/7/2014	7.43	n/a	n/a	n/a	n/a
		Hose Bib	B4867_HB2	9/7/2014	4.57J	n/a	n/a	n/a	n/a
		Hose Bib	B4867_HB3	9/7/2014	1.57J	n/a	n/a	n/a	n/a
		Hose Bib	B4867_HB1_SERV_CONN	9/7/2014	7.05	n/a	n/a	n/a	n/a
		Sink	B4867_GRR_S1	9/7/2014	1.91J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B4867_BB4	9/7/2014	8.35	n/a	n/a	n/a	n/a
3493	Murphy Canyon - Kids Connection	Sink	B3493_CLOSET_S1	9/7/2014	1.50J	n/a	n/a	n/a	n/a
		Sink	B3493_KITCHEN_S1	9/7/2014	0.756J	n/a	n/a	n/a	n/a
		Sink	B3493_MULTIPRPOSE_S1	9/7/2014	1.35J	n/a	n/a	n/a	n/a
		Sink	B3493_WOMENS_RR_S1	9/7/2014	0.921J	n/a	n/a	n/a	n/a
		Sink	B3493_WOMENS_RR_S2	9/7/2014	1.65J	n/a	n/a	n/a	n/a
		Sink	B3493_MENS_RR_S1	9/7/2014	1.56J	n/a	n/a	n/a	n/a
		Sink	B3493_MENS_RR_S2	9/7/2014	1.27J	n/a	n/a	n/a	n/a
		Sink	B3493_TINYTOTS_RM_S1	9/7/2014	0.710J	n/a	n/a	n/a	n/a
		Sink	B3493_TINYTOTS_RR_S1	9/7/2014	0.715J	n/a	n/a	n/a	n/a
		Sink	B3493_TINYTOTS_RR_S2	9/7/2014	1.23J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3493_BB1	9/7/2014	0.332J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3493_BB2	9/7/2014	0.294J	n/a	n/a	n/a	n/a
Service Connection	B3493_TTS_RR_S1_SVCN	10/4/2014	0.734J	n/a	n/a	n/a	n/a		
1876	Bayview Hills Community Center	Sink	B1876_KITCHEN_S1	9/21/2014	n/a	n/a	n/a	n/a	n/a
		Sink	B1876_HEATER_S1	9/21/2014	1.66J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B1876_BB1	9/21/2014	1.13J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B1876_BB2	9/21/2014	0.491J	n/a	n/a	n/a	n/a
		Sink	B1876_GIRLS_RR_S1	9/21/2014	1.47J	n/a	n/a	n/a	n/a
		Sink	B1876_GIRLS_RR_S2	9/21/2014	1.17J	n/a	n/a	n/a	n/a
		Sink	B1876_GIRLS_RR_S3	9/21/2014	1.36J	n/a	n/a	n/a	n/a
		Sink	B1876_BOYS_RR_S1	9/21/2014	3.23J	n/a	n/a	n/a	n/a
		Sink	B1876_BOYS_RR_S2	9/21/2014	2.03J	n/a	n/a	n/a	n/a
		Sink	B1876_BOYS_RR_S3	9/21/2014	1.42J	n/a	n/a	n/a	n/a
		Sink	B1876_TEEN_S1	9/21/2014	1.50J	n/a	n/a	n/a	n/a
Hose Bib	B1876_HB1	9/21/2014	1.70J	n/a	n/a	n/a	n/a		

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
		Bubbler Fountain	B1876_BB3	9/21/2014	1.37J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B1876_BB4	9/21/2014	0.631J	n/a	n/a	n/a	n/a
		Sink	B1876_GIRLS_RR_S1_SERV	9/21/2014	0.877J	n/a	n/a	n/a	n/a
		Hose Bib	B1876_HB2	9/21/2014	16.6	n/a	n/a	n/a	n/a
		Hose Bib	B1876_HB3	9/21/2014	0.878J	n/a	n/a	n/a	n/a

6205	Cholla	Sink	B6205_R107_S1A	9/20/2014	2.17J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_108_S4	9/20/2014	1.42J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_107_S5	9/20/2014	1.22J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_107_S4	9/20/2014	1.08J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_108_S5	9/20/2014	1.43J	n/a	n/a	n/a	n/a
		Sink	B6205_KITCHEN_S7	9/20/2014	1.05J	n/a	n/a	n/a	n/a
		Hose Bib	B6205_HB8	9/20/2014	1.04J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_109_S3A	9/20/2014	0.657J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_109_S5	9/20/2014	0.999J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_109_S4	9/20/2014	1.14J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_106_S5	9/20/2014	1.79J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B6205_BB1	9/20/2014	3.73J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B6205_BB2	9/20/2014	5.09	n/a	n/a	n/a	n/a
		Sink	B6205_STAFFLOUNGE_S1	9/20/2014	0.696J	n/a	n/a	n/a	n/a
		Sink	B6205_KITCHEN_S1	9/20/2014	2.00J	n/a	n/a	n/a	n/a
		Sink	B6205_KITCHEN_S2	9/20/2014	4.82J	n/a	n/a	n/a	n/a
		Sink	B6205_KITCHEN_S3	9/20/2014	0.692J	n/a	n/a	n/a	n/a
		Sink	B6205_KITCHEN_SP3	9/20/2014	0.769J	n/a	n/a	n/a	n/a
		Sink	B6205_KITCHEN_S5	9/20/2014	1.48J	n/a	n/a	n/a	n/a
		Sink	B6205_KITCHEN_S6	9/20/2014	5.50	n/a	n/a	n/a	n/a
		Sink	B6205_JANITORS_RM_S1	9/20/2014	0.586J	n/a	n/a	n/a	n/a
		Sink	B6205_LAUNDRY_S1	9/20/2014	3.36J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_101_S1	9/20/2014	1.51J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_101_S1A	9/20/2014	2.24J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_101_S2	9/20/2014	1.97J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_102_S1	9/20/2014	1.36J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_102_S1A	9/20/2014	3.87J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_102_S2	9/20/2014	0.908J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_103_S1	9/20/2014	0.662J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_103_S1A	9/20/2014	0.703J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_103_S2	9/20/2014	0.723J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_104_S1	9/20/2014	0.772J	n/a	n/a	n/a	n/a
Sink	B6205_RM_104_S1A	9/20/2014	1.60J	n/a	n/a	n/a	n/a		
Sink	B6205_RM_104_S2	9/20/2014	0.844J	n/a	n/a	n/a	n/a		
Sink	B6205_RM_105_S1	9/20/2014	0.766J	n/a	n/a	n/a	n/a		

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
0203	Heights CDC	Sink	B6205_RM_105_S1A	9/20/2014	1.68J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_105_S2	9/20/2014	0.757J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_106_S1	9/20/2014	0.618J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_106_S2	9/20/2014	1.01J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_106_S2A	9/20/2014	0.763J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_106_S3	9/20/2014	0.843J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_107_S1	9/20/2014	0.809J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_107_S2	9/20/2014	0.675J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_107_S3	9/20/2014	0.964J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_107_S3A	9/20/2014	0.891J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_108_S1	9/20/2014	1.06J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_108_S2	9/20/2014	0.792J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_108_S2A	9/20/2014	0.724J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_108_S3	9/20/2014	0.770J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_109_S1	9/20/2014	1.55J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_109_S2	9/20/2014	0.748J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_109_S2A	9/20/2014	0.967J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_109_S3	9/20/2014	0.707J	n/a	n/a	n/a	n/a
		Hose Bib	B6205_HB2	9/20/2014	1.77J	n/a	n/a	n/a	n/a
		Hose Bib	B6205_HB3	9/20/2014	3.12J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B6205_BB3	9/20/2014	1.85J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B6205_BB4	9/20/2014	0.653J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B6205_BB5	9/20/2014	0.731J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B6205_BB6	9/20/2014	2.02J	n/a	n/a	n/a	n/a
		Service Connection	B6205_KITCHN6_SRVCN	9/20/2014	0.448J	n/a	n/a	n/a	n/a
		Sink	B6205_STAFFLOUNGE_S1A	9/20/2014	2.41J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_106_S3A	9/20/2014	0.777J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_101_S3	9/20/2014	1.38J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_105_S3	9/20/2014	1.13J	n/a	n/a	n/a	n/a
		Sink	B6205_RM_102_S3	9/20/2014	5.17	n/a	n/a	n/a	n/a
Sink	B6205_RM_103_S3	9/20/2014	0.939J	n/a	n/a	n/a	n/a		
Sink	B6205_RM_104_S3	9/20/2014	0.940J	n/a	n/a	n/a	n/a		
Sink	B6205_RM_106_S4	9/20/2014	1.37J	n/a	n/a	n/a	n/a		
Sink	B6205_RM_108_S3A	9/20/2014	2.08J	n/a	n/a	n/a	n/a		

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
3295	Murphy Canyon CDC I	Sink	B3295_ROOM_4_S1	9/21/2014	10	n/a	n/a	n/a	n/a
		Sink	B3295_ROOM_4_S1A	9/21/2014	0.690J	n/a	n/a	n/a	n/a
		Sink	B3295_ROOM_5_S1	9/21/2014	0.677J	n/a	n/a	n/a	n/a
		Sink	B3295_ROOM_5_S1A	9/21/2014	5.48	n/a	n/a	n/a	n/a
		Sink	B3295_ROOM_6_S1	9/21/2014	0.735J	n/a	n/a	n/a	n/a
		Sink	B3295_ROOM_6_S1A	9/21/2014	5.99	n/a	n/a	n/a	n/a
		Sink	B3295_RM5_RM6_RR_S1	9/21/2014	3.06J	n/a	n/a	n/a	n/a
		Sink	B3295_RM5_RM6_RR_S2	9/21/2014	1.00J	n/a	n/a	n/a	n/a
		Sink	B3295_RM5_RM6_RR_S3	9/21/2014	2.51J	n/a	n/a	n/a	n/a
		Hose Bib	B3295_HB2	9/21/2014	4.09J	n/a	n/a	n/a	n/a
		Hose Bib	B3295_HB3	9/21/2014	4.63J	n/a	n/a	n/a	n/a
		Hose Bib	B3295_HB4	9/21/2014	1.94J	n/a	n/a	n/a	n/a
		Hose Bib	B3295_HB5	9/21/2014	9.06	n/a	n/a	n/a	n/a
		Hose Bib	B3295_HB6	9/21/2014	0.602J	n/a	n/a	n/a	n/a
		Hose Bib	B3295_HB7	9/21/2014	6.74	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3295_BB3	9/21/2014	0.356J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3295_BB4	9/21/2014	0.738J	n/a	n/a	n/a	n/a
		Service Connection	B3295_RR_S1_SERVCONN	9/21/2014	0.581J	n/a	n/a	n/a	n/a
		Sink	B3295_JANITOR_S1	9/21/2014	13.3	n/a	n/a	n/a	n/a
		Hose Bib	B3295_HB1	10/4/2014	45.4	n/a	n/a	Cap and secure	Never been used to consume water. Line capped by Lincoln Family Housing on 09Oct14
		Service Connection	B3295_HB1_SERV_CONN	10/4/2014	2.39J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3295_BB1	9/21/2014	0.307J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3295_BB2	9/21/2014	0.275J	n/a	n/a	n/a	n/a
		Sink	B3295_RR_S1	9/21/2014	0.334J	n/a	n/a	n/a	n/a
		Sink	B3295_STAFFLOUNGE_S1	9/21/2014	0.812J	n/a	n/a	n/a	n/a
		Sink	B3295_WR_S1	9/21/2014	0.562J	n/a	n/a	n/a	n/a
		Sink	B3295_KITCHEN_S1	9/21/2014	10.4	n/a	n/a	n/a	n/a
		Sink	B3295_KITCHEN_S2	9/21/2014	3.93J	n/a	n/a	n/a	n/a
		Sink	B3295_KITCHEN_S3	9/21/2014	0.823J	n/a	n/a	n/a	n/a
		Sink	B3295_ROOM_1_S1	9/21/2014	0.620J	n/a	n/a	n/a	n/a
		Sink	B3295_ROOM_1_S1A	9/21/2014	17.0	n/a	n/a	n/a	n/a
		Sink	B3295_RR1_S1	9/21/2014	0.379J	n/a	n/a	n/a	n/a
Sink	B3295_RR2_S1	9/21/2014	0.505J	n/a	n/a	n/a	n/a		
Sink	B3295_ROOM_2_S1	9/21/2014	0.604J	n/a	n/a	n/a	n/a		
Sink	B3295_ROOM_2_S1A	9/21/2014	15.9	n/a	n/a	n/a	n/a		
Sink	B3295_CLOSET_S1	9/21/2014	1.39J	n/a	n/a	n/a	n/a		
Sink	B3295_ROOM_3_S1	9/21/2014	0.890J	n/a	n/a	n/a	n/a		
Sink	B3295_ROOM_3_S1A	9/21/2014	18.2	n/a	n/a	n/a	n/a		

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
		Sink	B3295_RM3_RM4_RR_S1	9/21/2014	2.43J	n/a	n/a	n/a	n/a
		Sink	B3295_RM3_RM4_RR_S2	9/21/2014	0.746J	n/a	n/a	n/a	n/a
		Sink	B3295_RM3_RM4_RR_S3	9/21/2014	2.24J		n/a	n/a	n/a

3125	Murphy Canyon CDC II	Sink	B3125_A119_TDLRS_S1	4/23/2015	0.953J	n/a	n/a	n/a	n/a
		Sink	B3125_A119_TDLRS_S2	4/23/2015	2.13J	n/a	n/a	n/a	n/a
		Sink	B3125_A119_TDLRS_S2A	4/23/2015	3.47J	n/a	n/a	n/a	n/a
		Sink	B3125_A119_TDLRS_S3	4/23/2015	3.02J	n/a	n/a	n/a	n/a
		Sink	B3125_A119_TDLRS_S4	4/23/2015	0.708J	n/a	n/a	n/a	n/a
		Sink	B3125_A115_PRCL_S1	4/23/2015	0.648J	n/a	n/a	n/a	n/a
		Sink	B3125_A115_PRCL_S2	4/23/2015	2.49J	n/a	n/a	n/a	n/a
		Sink	B3125_A115_PRCL_S2A	4/23/2015	3.56J	n/a	n/a	n/a	n/a
		Sink	B3125_A115_PRCL_S3	4/23/2015	2.68J	n/a	n/a	n/a	n/a
		Sink	B3125_A115_PRCL_S4	4/23/2015	1.44J	n/a	n/a	n/a	n/a
		Sink	B3125_A122_PRCL_S1	4/23/2015	0.673J	n/a	n/a	n/a	n/a
		Sink	B3125_A122_PRCL_S2	4/23/2015	1.79J	n/a	n/a	n/a	n/a
		Sink	B3125_A122_PRCL_S2A	4/23/2015	2.05J	n/a	n/a	n/a	n/a
		Sink	B3125_A122_PRCL_S3	4/23/2015	0.712J	n/a	n/a	n/a	n/a
		Sink	B3125_A122_PRCL_S4	4/23/2015	0.936J	n/a	n/a	n/a	n/a
		Sink	B3125_A128_PRCL_S1	4/23/2015	0.241J	n/a	n/a	n/a	n/a
		Sink	B3125_A128_PRCL_S2	4/23/2015	1.55J	n/a	n/a	n/a	n/a
		Sink	B3125_A128_PRCL_S2A	4/23/2015	0.212J	n/a	n/a	n/a	n/a
		Sink	B3125_A128_PRCL_S3	4/23/2015	0.611J	n/a	n/a	n/a	n/a
		Sink	B3125_A128_PRCL_S4	4/23/2015	1.21J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_S1	4/23/2015	1.60J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_S2	4/23/2015	0.323J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_S3	4/23/2015	0.390J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_S4	4/23/2015	1.30J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_S5	4/23/2015	0.289J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_S6	4/23/2015	0.428J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_S7	4/23/2015	0.381	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_SP1	4/23/2015	0.184J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_SP2	4/23/2015	0.165J	n/a	n/a	n/a	n/a
		Sink	B3125_A138_KTCHN_SP3	4/23/2015	0.162J	n/a	n/a	n/a	n/a
		Sink	B3125_A131_TDLRS_S1	4/23/2015	0.230J	n/a	n/a	n/a	n/a
		Sink	B3125_A131_TDLRS_S2	4/23/2015	2.33J	n/a	n/a	n/a	n/a
		Sink	B3125_A131_TDLRS_S2A	4/23/2015	1.03J	n/a	n/a	n/a	n/a
Sink	B3125_A131_TDLRS_S3	4/23/2015	1.42J	n/a	n/a	n/a	n/a		
Sink	B3125_A131_TDLRS_S4	4/23/2015	1.52J	n/a	n/a	n/a	n/a		
Sink	B3125_A125_TDLRS_S1	4/23/2015	0.670J	n/a	n/a	n/a	n/a		
Sink	B3125_A125_TDLRS_S2	4/23/2015	3.11J	n/a	n/a	n/a	n/a		
Sink	B3125_A125_TDLRS_S2A	4/23/2015	3.56J	n/a	n/a	n/a	n/a		

Building	Facility Name	Outlet Type	Sample Name	Initial Sample Date	Initial Sample Reading (ppb)	First Draw Sample	30-Sec Flush	Proposed Corrective Action	Corrective Action Planned/Completed
		Sink	B3125_A125_TDLRS_S3	4/23/2015	1.41J	n/a	n/a	n/a	n/a
		Sink	B3125_A125_TDLRS_S4	4/23/2015	0.927J	n/a	n/a	n/a	n/a
		Sink	B3125_A136_LNDRY_S1	4/23/2015	1.01J	n/a	n/a	n/a	n/a
		Hose bib	B3125_A134_JANTR_HB3	4/23/2015	8.14	n/a	n/a	n/a	n/a
		Sink	B3125_A134_JNTR_S1	4/23/2015	2.18J	n/a	n/a	n/a	n/a
		Refrigerator	B3125_A117_BKSTF_R1	4/23/2015	2.29J	n/a	n/a	n/a	n/a
		Sink	B3125_A117_BKSTF_S1	4/23/2015	2.60J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3125_BB1	4/23/2015	0.181J	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3125_BB2	4/23/2015	0.0928J	n/a	n/a	n/a	n/a
		Hose bib	B3125_HB1	4/23/2015	19.2	n/a	n/a	n/a	n/a
		Hose bib	B3125_HB2	4/23/2015	9.87	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3125_BB4	4/23/2015	0.137J	n/a	n/a	n/a	n/a
		Hose bib	B3125_HB4	4/23/2015	9.48	n/a	n/a	n/a	n/a
		Bubbler Fountain	B3125_BB3	4/23/2015	0.203J	n/a	n/a	n/a	n/a
		Hose bib	B3125_HB5	4/23/2015	11	n/a	n/a	n/a	n/a
		Hose bib	B3125_HB6	4/23/2015	0.535J	n/a	n/a	n/a	n/a
		Service Connection	B3125_A108_HB6_SRVCN	4/23/2015	0.0745J	n/a	n/a	n/a	n/a